



Req.No	Req. Date	Location	Inv. No	Item Name	Complaint	Status	Remarks
View	AC22071864	01-07-2022	Nursing Students Hostel KPTR Campus	NA	COOLER	Hostel Mess side Water cooler not working to be repaired (Urgent)	Completed recomended for condemnation
View	AC22051282	10-05-2022	FTM Library	NA	AC	Library AC tripper not working to be repaired	Completed Gas leak arrested
View	AC2204986	18-04-2022	Students Nurses Hostel	NA	AC	Water Cooler not working properly to be repaired	Completed spare not available in the market
View	AC2204916	11-04-2022	College of Nursing KPTR Campus	NA	AC	Board Room AC not working to be repaired	Completed out door wire damage was rectified
View	AC22041091	26-04-2022	College of Nursing KPTR Campus	NA	AC	FTM Library AC filter to be clean	Completed filter cleaing done
View	AC2203772	30-03-2022	College of Nursing KPTR Campus	NA	FRIDGE	Fridge to be condemned	Completed condemnation done
View	AC2203656	23-03-2022	College of Nursing KPTR Campus	NA	FRIDGE	Fridge not working to be repaired	Completed compressor condensor and freezer changed since fridge freezer coil was punched by user dept
View	AC220141	07-01-2022	College of Nursing KPTR Campus	NA	AC	Hostel GYM room AC new remote to be provide	Completed new remote replaced on 12.01.2022
View	AC2201110	19-01-2022	College of Nursing	NA	FRIDGE	Fridge not working to be repaired	Completed wiring corrected
View	AC21113327	12-11-2021	College of Nursing KPTR Campus	NA	AC	AC Stablizer to be fixed in library	Completed stabilizer fixing done
View	AC21113297	10-11-2021	College of Nursing KPTR Campus	NA	AC	Server Room AC not working properly to be checked (urgent)	Completed gas leak arrested
View	AC21103096	21-10-2021	Students Hostel KPTR Campus	NA	AC	Hostel GYM AC to be service (work done)	Completed filter cleaning done
View	AC21103069	20-10-2021	College Library KPTR Campus	NA	AC	Library AC not working to be repaired	Completed stabilizer directed
View	AC21103012	15-10-2021	College Library KPTR Campus	NA	AC	Library AC to be service	Completed All A.Cs filter cleaning and out doors service done - David & Bala Krishnan
View	AC21092561	06-09-2021	College of Nursing KPTR Campus	NA	AC	Board Room AC not working to be repaired	Completed Cable damaged by squireel was rectified
View	AC21072105	26-07-2021	College of Nursing KPTR Campus	NA	AC	CNE Lecture Hall AC Stablizer Fell down to be repaired(urgent)	Completed stabilizer fixed properly
View	AC21071987	15-07-2021	College of Nursing KPTR Campus	NA	AC	Board Room AC not working to be repaired	Completed Squireiel damaged the wire, wiring corrected
View	AC21071959	13-07-2021	Nursing students hostel	NA	COOLER	UG - 3rd, 5th, 6th, 8th floor Water cooler is over flowing. urgent.. Equipment Sent : No , Contact Person:Ms .Sheela/Telephone No:7260 Engg Rmarks REF: AC&REF	Completed 2nos Thermostat changed
View	AC21071874	06-07-	College of	NA	FRIDGE	Fundamental Dept. Fridge not working to be	Completed Card wire

		2021	Nursing KPTR Campus			repaired		changed
View	AC2104986	09-04-2021	College of Nursing KPTR Campus	NA	FRIDGE	Fundamental Dept. Fridge not working to be repaired (urgent)	Completed	electrical problem rectified
View	AC21041084	19-04-2021	College of Nursing KPTR Campus	NA	AC	AC Stabilizer to be fixed	Completed	stabilizer fixed
View	AC2103797	29-03-2021	College of Nursing KPTR Campus	NA	AC	CNE Lecturer Hall AC not working to be repaired	Completed	2nos stabilizer problem, directed
View	AC2102482	26-02-2021	College of Nursing KPTR Campus	NA	AC	GFATM Lecture Hall AC to be cleaned	Completed	filter cleaning done
View	AC2102481	26-02-2021	College of Nursing KPTR Campus	NA	AC	Board Room AC to be cleaned	Completed	Filter cleaning done
View	AC20122911	22-12-2020	College Library	NA	AC	College Library AC to be serviced(work done)	Completed	All A.Cs filter cleaning done
View	AC20122837	11-12-2020	College of Nursing, Kagithapet	NA	AC	CNE Lecturer Hall AC not working	Completed	PCB REpaired
View	AC20102248	07-10-2020	STUDENT HOSTEL KPTR CAMPUS	NA	Cooler - UG block	Near R-507,514 cooler plug point has to be repaired(urgent)	Completed	Pin top changed
View	AC20102247	07-10-2020	STUDENT HOSTEL KPTR CAMPUS	NA	Cooler - UG block	Near R-615 Cooler plug point has to be repaired(urgent)	Completed	Pin top changed
View	AC20102246	07-10-2020	STUDENT HOSTEL KPTR CAMPUS	NA	Cooler - UG block	Near R-407 cooler plug point has to be fixed(urgent)	Completed	Pin top changed
View	AC20102245	07-10-2020	STUDENT HOSTEL KPTR CAMPUS	NA	Cooler - UG block	Near R-807 water cooler wire with plug point has to be repaired(urgent)	Completed	Pin top changed
View	AC20102244	07-10-2020	STUDENT HOSTEL KPTR CAMPUS	NA	Cooler - UG block	Near R-707 cooler plug point top has to be repaired(urgent)	Completed	Pin top changed
View	AC20102241	06-10-2020	STUDENT HOSTEL KPTR CAMPUS	NA	Water Cooler - UG Block	Near Room 815 Water Cooler Hose to be fixed new(urgent)	Completed	hose was fixed
View	AC20102239	06-10-2020	STUDENT HOSTEL KPTR CAMPUS	NA	Refrigerator - Mess	In Kitchen Refrigerator has to be repaired(urgent)	Completed	Checked and found that fridge is working well
View	AC20092112	22-09-2020	College of Nursing, Kagithapet	NA	AC	GFATM Lecturer Hall AC water Leaking to be repaired	Completed	AC Drain block released and drain pipeline cleaned
View	AC20092066	16-09-2020	STUDENT HOSTEL KPTR CAMPUS	CYTO-U00N0011	Refrigerator	In Kitchen, Refrigerator has to be repaired(urgent)	Completed	Compressor starting ready and newly fixed
View	AC20061474	22-06-2020	Community Health Nursing	NA	FRIDGE	Temperature monitor to be repaired	Completed	Fan motor rewinding
View	AC20061325	02-06-2020	College of Nursing, Kagithapet	NA	COOLER	Walk in cooler(Vegetables) not working to be repaired(very urgent)	Completed	36 MFD running capacitor changed by yuvaraj and saravanan
View	AC20051171	20-05-	College of	NA	FRIDGE	Community Department Fridge not working	Completed	Item not

		2020	Nursing, Kagithapet					available in the market
View	AC2003724	20-03-2020	College of Nursing, Kagithapet	NA	AC	GFATM Lecturer Hall AC to be cleaned	Completed	4 Nos Cassette type AC indoor filters cleaned
View	AC2003531	03-03-2020	College of Nursing, Kagithapet	NA	AC	Board Room AC not working to be repaired	Completed	Out going main card wire, so wire adjusted
View	AC2002297	04-02-2020	College of Nursing, Kagithapet	NA	AC	Server Room AC not working to be repaired(urgent)	Completed	Compressor newly fixed and gas charged done
View	AC2001197	24-01-2020	New Hostel Kagithapattarai	NA	FRIDGE	Hostel Fridge stand is broken to be repaired(urgent)	Completed	2 Nos Fridge leg newly replaced
View	AC2001110	13-01-2020	Library, Kagithapattarai	NA	AC	Library AC to be serviced	Completed	Compressor new fixed and gas charging done by srinivasan and saravanan
View	AC19123397	14-12-2019	Library, Kagithapattarai	NA	AC	Library AC Not working properly to be repaired	Completed	Compressor changed
View	AC19113215	19-11-2019	Library, Kagithapattarai	NA	AC	Computer Lab AC cooling very slow to be repaired	Completed	Gas leak problem is rectified by daniel and prabhakaran
View	AC19113093	06-11-2019	STUDENT HOSTEL KPTR CAMPUS	NA	COOLER	In UG block and PG block mess L-bend with hose pipe is to be fixed for water coolers .(urgent)	Completed	Drainage extension provided by devan
View	AC19113092	06-11-2019	STUDENT HOSTEL KPTR CAMPUS	NA	COOLER	In PG block L-bend with hose pipe is to be fixed for all water coolers.(urgent)	Completed	Drainage extension provided by devan
View	AC19113091	06-11-2019	STUDENT HOSTEL KPTR CAMPUS	NA	COOLER	IN UG mess L-bend with hose pipe is to be fixed for all water coolers.(urgent)	Completed	Drainage extension provided by devan
View	AC19102778	04-10-2019	College of Nursing, Kagithapet	NA	AC	Board Room AC not cooling properly to be repaired	Completed	AC unit fully checked
View	AC19092653	20-09-2019	College of Nursing, Kagithapet	NA	AC	College Board Room AC Not working properly to be repaired	Completed	AC filters cleaned
View	AC19092581	13-09-2019	STUDENT HOSTEL KPTR CAMPUS	NA	STABILIZER	in PG block in room no D700 AC stabilizer is to be fixed.(urgent). Equipment Sent : No , Contact Person:Mrs.Sruthi/Telephone No:7260 Engg Rmarks REF: AC&REF	Completed	AC stabilizer fixed
View	AC19082355	23-08-2019	College of Nursing, Kagithapet	NA	FRIDGE	Dean office fridge not working to be repaired(very urgent)	Completed	Compressor grounded, Old refrigerator and hence recomended for condemnation
View	AC19082207	06-08-2019	STUDENT HOSTEL KPTR CAMPUS	NA	WATER COOLER	in UG block the cooler near room no 615 is not working .it should be repaired. Equipment Sent : No , Contact Person:Mrs.Sruthi/Telephone No:7260 Engg Rmarks REF: AC &REF	Completed	Thermostat changed
View	AC19082168	02-08-2019	students hostel KPTR campus	NA	WATER COOLER	in UG block in 6th floor near room no 614 water cooler float ball is broken. it has to be fixed.. Equipment Sent : No , Contact	Completed	Float ball changed

						Person:MRS.SRUTHI/Telephone No:7260 Engg Rmarks REF: AC&R		
View	AC19072121	27-07-2019	College of Nursing, CNE & Research Department	NA	AC	To be serviced	Completed	4 AC units gas topup done
View	AC19072034	17-07-2019	College of Nursing, Kagithapet	NA	AC	CNE Lecture Hall AC water leaking inside to be repaired(very urgent)	Completed	AC water leak arrested
View	AC19061855	28-06-2019	students hostel KPTR campus	NA	COOLER	in PG block water cooler near room no D702 plug point to be fixed.(URGENT). Equipment Sent : No , Contact Person:MRS.SRUTHI/Telephone No:7260 Engg Rmarks REF: AC&R	Completed	PIntop already fixed
View	AC19061754	19-06-2019	Library, Kagithapattarai	NA	AC	AC is not working properly	Completed	AC gas topup done and one A.C coil sensor changed
View	AC19061753	19-06-2019	College of Nursing, Kagithapet	NA	COOLER	To be serviced	Completed	Checked library cooler problem is working
View	AC19051531	31-05-2019	STUDENT HOSTEL KPTR CAMPUS	NA	COOLER	in UG block 2nd floor, water cooler is not working. it should be checked(URGENT)	Completed	Thermostat changed
View	AC19051530	31-05-2019	STUDENT HOSTEL KPTR CAMPUS	NA	COOLER	in UG block 6th loor water cooler is not working properly. it should be checked. (urgent).	Completed	thermostat changed
View	AC19051529	31-05-2019	STUDENT HOSTEL KPTR CAMPUS	NA	COOLER	in UG block 8th floor cooler is not working.it should be repaired.	Completed	
View	AC19051330	17-05-2019	STUDENT HOSTEL KPTR CAMPUS	NA	WATER COOLER	THE COOLER ADJACENT TO WARDENS ROOM IS NOT WORKING PROPERLY.IT HAS TO BE CHECKED(UG BLOCK). Equipment Sent : No , Contact Person:Mrs.Sruthi/Telephone No:7260 Engg Rmarks REF: AC & Ref	Completed	thermostat changed
View	AC19051314	17-05-2019	STUDENT HOSTEL KPTR CAMPUS	NA	WATER COOLER	IN PG MESS WATER COOLER IS NOT WORKING. IT HAS TO BE REPAIRED. Equipment Sent : No , Contact Person:Mrs.Sruthi/Telephone No:7260 Engg Rmarks REF: AC & Ref	Completed	thermostat changed
View	AC19051229	13-05-2019	College of Nursing, Kagithapet	NA	AC	Board Room AC wiring side squirrel there inside to be removed(urgent)	Completed	AC problem is rectified by srinivasan
View	AC19051130	03-05-2019	STUDENT HOSTEL KPTR CAMPUS	NA	WATER COOLER	NEAR ROOM NO 212 WATER COOLER PLUG TOP IS TO BE FIXED(UG BLOCK). Equipment Sent : No , Contact Person:Mrs.Sruthi/Telephone No:7260 Engg Rmarks REF: AC & Ref	Completed	thermostat changed
View	AC1903696	28-03-2019	College of Nursing, Kagithapet	NA	AC	GFATM Lecturer Hall AC not working to be repaired(urgent)	Completed	Power problem is rectified
View	AC1903541	12-03-2019	College of Nursing, Kagithapet	NA	AC	Board Room AC Not cooling(Urgent)	Completed	Gas leak arrested
View	AC1903465	07-03-2019	College of Nursing, Kagithapet	NA	AC	Board Room & GFATM Lecturer Hall AC to be cleaned	Completed	Gas leak is rectified by daniel and babu
View	AC1903427	02-03-2019	College of Nursing, Kagithapet	NA	AC	AC to be service cleaning	Completed	Ac service done on 10.03.19
View	AC18123138	31-12-	New Hostel	NA	water Cooler	Room no.707 near water cooler to be	Completed	Thermostat

		2018	Kagithapattarai			repaired(UG Block). Equipment Sent : No , Contact Person:Ms.Jothi sargunam/Telephone No:7260 Engg Rmarks REF: AC&REF		changed on 07.01.19
View	AC18123036	10-12-2018	New Hostel Kagithapattarai	NA	COOLER	Room no.703 near common floor water cooler is not working (PG Block)	Completed	Board fixed
View	AC18122980	01-12-2018	New Hostel Kagithapattarai	NA	COOLER	PG Dinning Hall water cooler is over flowing to be repaired	Completed	Float ball problem is rectified
View	AC18112909	20-11-2018	New Hostel Kagithapattarai	NA	COOLER	Ground floor dinning hall water cooler is over flowing to be repaired	Completed	Float ball adjusted on 27.11.18
View	AC18102659	16-10-2018	New Hostel Kagithapattarai	NA	COOLER	Room no.918 near water cooler is overflow to be repaired(PG Block)	Completed	Float ball problem is rectified on 19.10.18
View	AC18102650	15-10-2018	New Hostel Kagithapattarai	NA	COOLER	Room no.413 near water cooler is over flowing to be repaired(PG Block)	Completed	Water over flow is rectified on 19.10.18
View	AC18102614	09-10-2018	New Hostel Kagithapattarai	NA	COOLER	Room no.206 near water cooler to be repaired(UG Block)	Completed	TH adjusted
View	AC18082108	16-08-2018	New Hostel Kagithapattarai	NA	WATER COOLER	Room no.413 Water Cooler float ball to be check is overflowing (PG Block). Equipment Sent : No , Contact Person:Ms.Jothi sargunam/Telephone No:7260 Engg Rmarks REF: AC&REF	Completed	Float ball adjusted
View	AC18071839	16-07-2018	New Hostel Kagithapattarai	NA	WATER DISPENSER	Room no.815 near water cooler flot ball is broken(UG Block)	Completed	Flot ball fixed
View	AC18071757	06-07-2018	New Hostel Kagithapattarai	NA	AC	4th floor GYM AC is not working to be repaired(UG Block)(Very urgent)	Completed	Electrical and stabilizer problem is rectified
View	AC18061615	20-06-2018	New Hostel Kagithapattarai	NA	COOLER	PG BLock 1st floor water cooler to be serviced	Completed	Thermostat setting changed on 21.06.18
View	AC18061609	19-06-2018	New Hostel Kagithapattarai	NA	COOLER	Room no.811 near Water cooler not working to be repaired(PG Block)	Completed	Relay and OLP Chnaged on 21.06.18
View	AC18061451	04-06-2018	New Hostel Kagithapattarai	NA	COOLER	Room no.713 near Water Cooler to be repaired	Completed	Water cooler, relay changed
View	AC18051307	22-05-2018	New Hostel Kagithapattarai	NA	COOLER	Ground floor water cooler is not working (PG Block)	Completed	
View	AC1804952	20-04-2018	Kagithapattarai	NA	COOLER	Water Cooler not working to be repaired	Completed	TH Changed 5 AMPS plug changed
View	AC1804805	10-04-2018	New Hostel Kagithapattarai	NA	COOLER	UG dinning hall cooler to be repaired(UG Block)	Completed	TH Changed on 19.04.18
View	AC1804804	10-04-2018	New Hostel Kagithapattarai	NA	COOLER	PG Dinning hall cooler to be repaired(PG Block)	Completed	10 MFD capacitor changed on 19.04.18
View	AC1804749	05-04-2018	College of Nursing	NA	AC	Water leakage	Completed	There is no water leak when checked 2 times on 19.04.18
View	AC18041067	28-04-2018	Kagithapattarai	NA	AC	Library AC to be cleaned	Completed	Filters cleaning done on 11.05.18
View	AC1803538	19-03-2018	Kagithapattarai	NA	COOLER	College Water Cooler not working to be repaired(very urgent)	Completed	MFD Capacitor changed
View	AC1802305	19-02-2018	Kagithapattarai	NA	AC	Board Room AC not working that Consealed place open for your repair purpose kindly come and to be repaired(very urgent)	Completed	AC wire cut to be connected

View	AC1802249	09-02-2018	Kagithapattarai	NA	AC	Board Room AC not working to be repaired(very urgent)	Completed	Stabilizer removed, wire direct to AC
View	AC1802193	02-02-2018	kagithapattarai	NA	FRIDGE	Community Health Fridge to be repaired	Completed	Capacitor relay OLP changed
View	AC17123219	19-12-2017	New Hostel Kagithapattarai	NA	COOLER	Room no.206 near water cooler is not working	Completed	Cooler thermostat changed
View	AC17123212	18-12-2017	New Hostel Kagithapattarai	NA	COOLER	Room no.716 near water cooler is not working(UG Block)	Completed	New thermostat changed
View	AC17123211	18-12-2017	New Hostel Kagithapattarai	NA	COOLER	Room no.415 near water cooler is not working to be repaired(UG BLock)	Completed	New thermostat changed
View	AC17123163	09-12-2017	New Hostel Kagithapattarai	NA	Walk in cooler	Walk in cooler (vegetables) tube light is not burning to be repaired	Completed	New tubelight changed on 15.12.17
View	AC17123162	09-12-2017	n	NA	COOLER	Reminder 1 Water cooler under repair in UG block	Completed	Compressor replaced
View	AC17123117	01-12-2017	New Hostel, Kagithapattarai	NA	COOLER	Walk in cooler tube light is not burning	Completed	Tubelight changed
View	AC17113052	21-11-2017	Kagithapattarai	NA	FRIDGE	Community Dept. Fridge wire to be repaired	Completed	Compressor replaced
View	AC17112985	13-11-2017	New Hostel Kagithapattarai	NA	AC	Room no.800D AC is not working continously triped(PG BLock)	Completed	rat damaged the wire and it was rectified
View	AC17112984	13-11-2017	New Hostel Kagithapattarai	NA	AC	Room no.900D AC is not working (PG Block)	Completed	rat damaged the wire and it was rectified
View	AC17112937	03-11-2017	College of Nursing	NA	AC	Water leakage	Completed	AC service done on 07.11.17
View	AC17102802	21-10-2017	Kagithapattarai	NA	AC	Library AC water leakage to be checked	Completed	AC service done on 27.10.17
View	AC17102763	14-10-2017	College of Nursing	NA	AC	Water leakage	Completed	4 Nos AC filters cleaned
View	AC17092386	04-09-2017	New Hostel Kagithapattarai	NA	COOLER	Room no.906 near water cooler is not working(UG Block)	Completed	Blue star water cooler thermostat burnt
View	AC17082246	21-08-2017	New Hostel, Kagithapattarai	NA	COOLER	Room no.407 near cooler is not working(UG Block)	Completed	Thermostat changed
View	AC17071865	12-07-2017	New Hostel Kagithapattarai	NA	FREEZER	Defreezer is not working in kitchen(very urgent)	Completed	checked condensor cleaned
View	AC17061721	27-06-2017	New Hostel Kagithapattarai	NA	Water cooler	Room no.407 near water cooler is not working to be repaired	Completed	Thermostat changed
View	AC17061718	27-06-2017	New Hostel Kagithapattarai	NA	COOLER	room no 716 near water cooler is not working(UG Block)	Completed	New TH Fixed working good
View	AC17051367	23-05-2017	New Hostel Kagithapattarai	NA	COOLER	Room no.606 near water cooler is not working(UG Block)	Completed	thermost changed
View	AC17051270	16-05-2017	Kagithapattarai	NA	COOLER	Water Cooler not working to be repaired(very urgent)	Completed	wiring corrected
View	AC17051182	10-05-2017	New Hostel Kagithapattarai	NA	COOLER	UG BLock dinning hall water cooler is not working to be repaired	Completed	Thermostat changed
View	AC1704996	24-04-2017	Kagithapattarai	NA	AC	Library AC filter to be cleaned	Completed	Filters cleaning done by saravanan
View	AC1703573	20-03-2017	Kagithapattarai	NA	AC	Board room AC to be cleaned(urgent)	Completed	Filter cleaning done

JOB - SEARCH
ENGINEERING AC - Completed Jobs

Service Department : [Call Logged](#)[Active Jobs](#)[Completed Jobs](#)[Cancelled/Transferred Jobs](#)

	Req.No	Req. Date	Location	Inv. No	Item Name	Complaint	Status	Remarks
View	AC22071864	01-07-2022	Nursing Students Hostel KPTR Campus	NA	COOLER	Hostel Mess side Water cooler not working to be repaired (Urgent)	Completed	recomedned for condemnation
View	AC22051282	10-05-2022	FTM Library	NA	AC	Library AC tripper not working to be repaired	Completed	Gas leak arrested
View	AC2204986	18-04-2022	Students Nurses Hostel	NA	AC	Water Cooler not working properly to be repaired	Completed	spare not available in the market
		11-	College of					out door wire

Req.No	Req. Date	Location	Inv. No	Item Name	Complaint	Status	Remarks
View	CE220814202	13-08-2022	Student Nurses Hostel, Kagithapatrai	NA	DRIANAGE SYSTEM	UG 507 Near Bathroom Indian Toilet is blocked. It has to be removed.	Completed
View	CE220813835	09-08-2022	College of Nursing KPTR Campus	NA	Carpentry work	Reminder 1: CNE Lecture Hall door not working properly to be repaired	Completed
View	CE220813814	09-08-2022	College of Nursing KPTR Campus	NA	Carpentry work	CNE Department Main Door Lock not working properly to be repaired	Completed
View	CE220813674	06-08-2022	Student Nurses Hostel, Kagithapatrai	NA	DRIANAGE SYSTEM	In UG mess hand washing area drainage is blocked	Completed
View	CE220813547	04-08-2022	College of Nursing KPTR Campus	NA	Carpentry work	1st and 2nd floor curtain ROD to be fixed	Completed
View	CE220813526	04-08-2022	Student Nurses Hostel, Kagithapatrai	NA	Plumbing work	In UG block Warden Room Wash basin tap is Leaking.	Completed
View	CE220813444	03-08-2022	Student Nurses Hostel, Kagithapatrai	NA	DRIANAGE SYSTEM	In Mess, Vessels Washing area Drainage is Blocked.	Completed
View	CE220813370	02-08-2022	College of Nursing KPTR Campus	NA	Carpentry work	Psychiatric Mrs.Jeeva room door lock not working properly to be repaired	Completed
View	CE220813206	01-08-2022	Student Nurses Hostel, Kagithapatrai	NA	DRIANAGE SYSTEM	In UG Mess Hand Washing Area Draiage is Blocked.	Completed
View	CE220713179	30-07-2022	College of Nursing KPTR Campus	NA	Carpentry work	CNE Lecture Hall door very noising to be repaired	Completed
View	CE220713063	28-07-2022	Student Nurses Hostel, Kagithapatrai	NA	Carpentry work	UG 315 near 3rd Bathroom Latch to be fixed.	Completed

JOB - SEARCH
ENGINEERING ELECTRICAL - Active Jobs

Service Department : ELECTRICALCall LoggedActive JobsCompleted JobsCancelled/Transferred Jobs

	Req.No	Req. Date	Location	Inv. No	Item Name	Complaint	Status	Remarks
View	EE22086656	19-08-2022	Student Nurses Hostel, Kagithapatrai	NA	TUBE LIGHT	In UG 816 tubelight is not working, it has to be repaired	Pending	
View	EE22086655	19-08-2022	Student Nurses Hostel, Kagithapatrai	NA	FAN	In UG 903,314,109, 514, 701, 101 & 111 fan is not working, It has to be repaired	Pending	
View	EE22086543	15-08-2022	Student Nurses Hostel, Kagithapatrai	NA	TUBE LIGHT	ug room no 816 common light is not working	Pending	
View	EE22086542	15-08-2022	Student Nurses Hostel, Kagithapatrai	NA	TUBE LIGHT	In UG 504 studt light is not working, it has to be repaired	Pending	
View	EE22086541	15-08-2022	Student Nurses Hostel, Kagithapatrai	NA	FAN	In UG 306,616,816 & 402 fan is not working.It has to repaired	Pending	

Req.No	Req. Date	Location	Inv. No	Item Name	Complaint	Status	Remarks
View	ME22077291	22-07-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	B.P.APPARATUS	To be calibrated	Completed
View	ME22066328	27-06-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	WEIGHING SCALE	to be repaired	Completed
View	ME22066327	27-06-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	B.P.APPARATUS	To be calibrated	Completed
View	ME22065827	13-06-2022	Student Nurses Hostel, Kagithapatrai	NA	Boiler	Boiler Water pump Hose is leaking. It has to be changed	Completed New Boiler hose(4nos) were purchased on 16/06/2022 and immediately it was replaced in the Student nurses hostel. Job was done by R.Sathiamoorthy and Vedhanayagam on 16/06/2022
View	ME22065793	11-06-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	B.P.APPARATUS	To be calibrated	Completed
View	ME22065611	07-06-2022	Student Nurses Hostel, Kagithapatrai	NA	BOILER	Boiler Tube is not Working	Completed New Boiler hose(4nos) were purchased on 16/06/2022 and immediately it was replaced in the Student nurses hostel. Job was done by R.Sathiamoorthy and Vedhanayagam on 16/06/2022
View	ME22055111	23-05-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	OTOSCOPE	to be repaired	Completed
View	ME22055110	23-05-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	OPHTHALMASCOPE	Not working	Completed
View	ME22055109	23-05-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	B.P.APPARATUS	To be calibrated	Completed
View	ME22054816	16-05-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	B.P.APPARATUS	To be calibrated	Completed
View	ME22054660	10-05-2022	Student Nurses Hostel, Kagithapatrai	NA	BOILER	In the Mess Boiler handle is broken. It has to be changed.	Completed The boiler was dismantled from its original position and it was sent to Mechanical department on 19/05/2022. The handle of the boiler was founded with external cracks. Here it was welded and grinded. Job was completed on 19/05/2022

View	ME22054529	06-05-2022	Student Nurses Hostel, Kagithapatrai	NA	FLOUR MACHINE BELT	In Mess flour machine belt to be changed	Completed	
View	ME22054455	04-05-2022	COLLEGE OF NURSING	NA	ROLLING CHAIRS	High Back and rolling chairs wheel to be changed	Completed	12 numbers chair.20 no wheels and 3 base changed
View	ME22044157	27-04-2022	College of Nursing KPTR Campus	NA	Metal High Stool	Metal High Stool to be painted	Completed	
View	ME22044141	27-04-2022	College of Nursing KPTR Campus	NA	Metal Cabinet	Metal Cabinet broken to be repaired	Completed	
View	ME22044139	27-04-2022	Students Hostel Mess, KPTR Campus	NA	Metal Tralley	Metal Tralley wheel broken to be changed	Completed	
View	ME22043899	20-04-2022	Student Nurses Hostel, Kagithapatrai	NA	Copper Tube	In the Mess Gas stove copper tube to be chnaged.	Completed	New copper tube was replaced on 20/04/2022 . As a result of this Gas Leak was arrested
View	ME22033216	31-03-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	B.P.APPARATUS	To be repaired	Completed	
View	ME22033185	30-03-2022	College of Nursing KPTR Campus	NA	Metal Cabin	Metal Cabin Draw is broken to be repaired	Completed	
View	ME22033110	29-03-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	B.P.APPARATUS	To be repaired	Completed	
View	ME22033095	28-03-2022	Student Nurses Hostel, Kagithapatrai	NA	Mixie Jar	Mixie Jar is not working properly. It has to be repaired.	Completed	Brass Bush - 2 Nos Procured from a petti shop by RS on 28/3/22. Paid by me.
View	ME22033094	28-03-2022	Student Nurses Hostel, Kagithapatrai	NA	Mixer Grinder	Mixer Grinder is not working. It has to be repaired.	Completed	Shaft - 2 Nos Coupler 6 way- 1 No Procured from a petti shop by RS on 28/3/22. Paid by me.
View	ME22032900	23-03-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	B.P.APPARATUS	To be calibrated	Completed	
View	ME22032450	11-03-2022	College of Nursing KPTR Campus	NA	Metal Cupboard	Dean office Metal Cupboard to be painted	Completed	
View	ME22032449	11-03-2022	College of Nursing KPTR Campus	NA	Patient Stretcher	Patient metal Stretcher wheel broken to be repaired	Completed	
View	ME22032014	01-03-	Student Nurses	NA	Wheat Flour	Belt to be	Completed	Allotted to srinivasan/Velmurugan

		2022	Hostel, Kagithapatrai		Machine Belt	Changed. Urgent		
View	ME22021934	28-02-2022	Student Nurses Hostel, Kagithapatrai	NA	Exhaust Fan	In the Mess Exhaust Fan is not working.	Completed	The motor coil was rewinded and now the exhaust fan is working
View	ME22021933	28-02-2022	Student Nurses Hostel, Kagithapatrai	NA	Grinder	In the Mess Grinder is not working. Its running very slow. Urgent	Completed	Belt - 1 No
View	ME22021378	11-02-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	FILING CABINET IS NOT CLOSING PROPERLY	to be repaired	Completed	
View	ME22021267	09-02-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	WEIGHING SCALE	annual service	Completed	
View	ME2201495	18-01-2022	College of Nursing KPTR Campus	NA	High back chair	High back chair bottom to be changed	Completed	
View	ME2201493	18-01-2022	College of Nursing KPTR Campus	NA	Pride Chair	Pride chair bottom to be repaired	Completed	
View	ME211212159	29-12-2021	College of Nursing KPTR Campus	NA	Kettle(Water heater)	Kettle (Water heater) not working to be repaired	Completed	Allotted to MT on 05/01/2022
View	ME211211892	20-12-2021	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	IRON FILING CABINET	FILING CABINET IS NOT CLOSING PROPERLY	Completed	
View	ME211211287	01-12-2021	College of Nursing KPTR Campus	NA	Floor Scrubbing Machine	Floor Scrubbing machine not working properly to be repaired	Completed	Kindly send the item Checked and found the motor are defective, Moulded type. Informed user to contact supplier/company
View	ME211111230	30-11-2021	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	B.P.APPARATUS	to be repaired	Completed	
View	ME211111220	30-11-2021	College of Nursing KPTR Campus	NA	Metal Cupboard	Dean office Metal Cupboard to be painted	Completed	
View	ME211110247	03-11-2021	Student Nurses Hostel, Kagithapatrai	NA	Dosai Burner	In the Mess Dosai Burner is brokened. It has to be changed.	Completed	New burners replaced

Req.No	Req. Date	Location	Inv. No	Item Name	Complaint	Status	Remarks
View	CN22083520	16-08-2022	College of Nursing KPTR Campus	NA	TELEPHONE	Telephone not working to be repaired. Faulty Ph. no - 7005	Completed Job completed by CL3
View	CN22083489	12-08-2022	College of Nursing KPTR Campus	NA	TELEPHONE	Telephone not working to be repaired. Faulty Ph. no - 7002	Completed Job completed by CL3
View	CN22073249	22-07-2022	College of Nursing KPTR Campus	NA	Coller Mike	Coller Mike Adapter broken to be repaired. Equipment Sent : Yes , Contact Person:Mr.Saravanan/Telephone No:7003 Engg Rmarks maintained by Communications dept	Completed Informed to coll.of.Nursing to contact lking service team
View	CN22073246	22-07-2022	College of Nursing KPTR Campus	NA	Cordless Mike (new)	Cordless Mike not working to be repaired. Equipment Sent : Yes , Contact Person:Mr.Saravanan/Telephone No:7016 Engg Rmarks maintained by Communications dept	Completed Informed to col.of.nursing to contact lking service team
View	CN22062913	27-06-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	TELEPHONE	Not Working. Faulty Ph. no - 7015	Completed Job completed by Mr. Naveen.
View	CN22062771	16-06-2022	College of Nursing KPTR Campus	NA	TELEPHONE	Hostel Mess Telephone not working properly to be repaired. Faulty Ph. no - 7259	Completed Job completed by CL2 & Mr. Naveen.
View	CN22052473	30-05-2022	College of Nursing KPTR Campus	NA	TELEPHONE	CNE Dept. Telephone not working properly to be repaired. Faulty Ph. no - 7017	Completed CL2 & DANIEL WORK DONE
View	CN2203887	10-03-2022	1st Floor Surgical Nursing Department	NA	TELEPHONE	Not Working. Faulty Ph. no - 7038	Completed WORK COMPLETED BY CL2
View	CN22031166	29-03-2022	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	TELEPHONE	CABLE LOOSE CONNECTION. Faulty Ph. no - 7015	Completed CL2 & VISHU WORK DONE
View	CN22031138	28-03-2022	College of Nursing	NA	TELEPHONE	Provide Parallel Connection in the GFATM Lecture Hall. Faulty Ph. no - 7034	Completed PLS SEND THE LETTER TO GS OFFICE
View	CN22018	03-01-2022	College of Nursing KPTR Campus	NA	TELEPHONE	Telephone not working to be repaired. Faulty Ph. no - 7002	Completed Job Completed by CL2
View	CN220162	05-01-2022	College of Nursing	NA	TELEPHONE	Addl.Deputy Dean Telephone point broken to be repaired (urgent). Faulty Ph. no - 7009	Completed Job Completed by CL3
View	CN2201243	21-01-2022	College of Nursing KPTR Campus	NA	TELEPHONE	Keypad not working. Faulty Ph. no - 7005	Completed Job completed by CL3.
View	CN21123298	16-12-2021	College of Nursing KPTR Campus	NA	TELEPHONE	Telephone not working. Faulty Ph. no - 7006	Completed Service Done. Job Completed By CL4. H/O To Ms. Vanitha (attndr)
View	CN21123164	06-12-2021	College of Nursing KPTR Campus	NA	TELEPHONE	Alumni Office Telephone line not working to be repaired. Faulty Ph. no - 7034	Completed JOB COMPLETED BY CL2
View	CN21113067	29-11-2021	College of Nursing KPTR Campus	NA	TELEPHONE	Telephone receiver wire broken to be repaired. Faulty Ph. no - 7002	Completed JOB COMPLETED BY CL 2
View	CN21112797	10-11-2021	College of Nursing KPTR Campus	NA	TELEPHONE	Reminder 1: Telephone line not working to be repaired. Faulty Ph. no - 7024	Completed job completed by cl.3&4
View	CN21112727	01-11-2021	College of Nursing	NA	TELEPHONE	telephone line not working . Faulty Ph. no - 7005	Completed job completed by(cl-2)
View	CN21112725	01-11-2021	College of Nursing	NA	TELEPHONE	telephone line not working . Faulty Ph. no - 7027	Completed JOB COMPLETED BY CL2
View	CN21102573	20-10-2021	College of Nursing KPTR Campus	NA	TELEPHONE	Telephone wire problem to be repaired. Faulty Ph. no - 7013	Completed JOB COMPLETED

								BY CL-4
View	CN21092386	24-09-2021	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	TELEPHONE	Wire disconnected. Faulty Ph. no - 7015	Completed	job completed
View	CN21081977	16-08-2021	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	TELEPHONE	Wire disconnected. Faulty Ph. no - 7015	Completed	job completed
View	CN21071640	08-07-2021	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	TELEPHONE	Not Working. Faulty Ph. no - 7014	Completed	Phone Service in Exchinge by cl-3
View	CN21061551	23-06-2021	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	TELEPHONE	Not Working. Faulty Ph. no - 7014	Completed	job completed with cl.1(Dhanapal)
View	CN21061545	23-06-2021	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	TELEPHONE	No dial tone. Faulty Ph. no - 7015	Completed	job completed with cl.1(Dhanapal)
View	CN21051412	28-05-2021	College of Nursing	NA	TELEPHONE	No dial tone. Faulty Ph. no - 7036	Completed	faulty capsule replaced(jj)
View	CN21051358	17-05-2021	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	TELEPHONE	only incoming calls received . Faulty Ph. no - 7015	Completed	job completed
View	CN21051350	15-05-2021	College of Nursing KPTR Campus	NA	TELEPHONE	Community Dept. Telephone outgoing not working to be repaired(urgent). Faulty Ph. no - 7013	Completed	job completed
View	CN21041093	21-04-2021	Community Health Nursing Department, College of Nursing, CMC, Vellore	NA	TELEPHONE	CABLE LOOSE CONNECTION. Faulty Ph. no - 7015	Completed	job completed
View	CN2102550	26-02-2021	College of Nursing KPTR Campus	NA	TELEPHONE	Telephone line not working to be repaired(urgent). Faulty Ph. no - 7038	Completed	faulty cable pair replaced by cl.1&4
View	CN2102502	26-02-2021	College of Nursing KPTR Campus	NA	TELEPHONE	Telephone line not working to be repaired(urgent). Faulty Ph. no - 7024	Completed	job completed by cl.1&4(7024 and 7038)
View	CN2101219	28-01-2021	College of Nursing KPTR Campus	NA	TELEPHONE	phone not working (work done). Faulty Ph. no - 7004	Completed	phone serviced handed back (cl,3)
View	CN20101794	14-10-2020	College of Nursing, Kagithapet	NA	TELEPHONE	Deputy Dean Telephon line plug is broken to be changed(urgent). Faulty Ph. no - 7007	Completed	went to repair-but not allowed due to progress in exam,so returned back(cl2)
View	CN20081222	04-08-2020	College of Nursing, Kagithapet	NA	TELEPHONE	CNE Dept., HOD Telephone line not working to be repaired (urgent). Faulty Ph. no - 7017	Completed	job completed by cl.1
View	CN20071166	24-07-2020	College of Nursing, Kagithapet	NA	TELEPHONE	Telephone line not working. Faulty Ph. no - 7036	Completed	cable fault cabel pair changed(cl2)
View	CN20071165	24-07-2020	College of Nursing, Kagithapet	NA	TELEPHONE	Reminder 1: Telephone line not working. Faulty Ph. no - 7005	Completed	main cord pin changed(cl2)
View	CN20071142	21-07-2020	College of Nursing, Kagithapet	NA	TELEPHONE	General office telephone line not working to be repaired(urgent). Faulty Ph. no - 7005	Completed	Hanset pin replased by(cl2)
View	CN20071094	14-07-2020	College of Nursing, Kagithapet	NA	TELEPHONE	Reminder1:Telephone line not working (very urgent). Faulty Ph. no - 7022	Completed	faulty maincord pin replaced
View	CN20061031	30-06-2020	College of Nursing, Kagithapet	NA	TELEPHONE	Reminder 1:Telephone line not working to be repaired(urgent). Faulty Ph. no - 7022	Completed	faulty maincord pin replaced

View	CN20061000	23-06-2020	College of Nursing, Kagithapet	NA	TELEPHONE	Telephone line not working to be repaired(urgent). Faulty Ph. no - 7022	Completed	faulty maincord pin replace
------	------------	------------	--------------------------------	----	-----------	---	-----------	-----------------------------